## Garden State Laboratories, Inc.



Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director Jordan B. Klein, B.A., Exec. Vice President Sharon Ercoliani, B.A. Laboratory Manager Report of Analysis

410 Hillside Ave. Hillside, NJ 07205

Telephone: 800-273-8901 Email: info@gslabs.com Internet: www.gslabs.com

Main Lab NJDEP Lab Cert. #20044

Jersey Shore Lab NJDEP Lab Cert. #15037

Lakehurst Lab NJDEP Lab Cert. #15041

For: Hatikvah International Academy

> Charter School 7 Lexington Ave.

East Brunswick, NJ 08816

Laboratory Director:

Report Date: 08/13/2024

Attention:

Judith Babeu

Client Number: Lab Sample ID: HAT21

Sample ID:

Hatikvah International Academy Charter School - 7 Lexington

240805038-01

Ave., East Brunswick, NJ 08816/ Field Blank

Site:

Collection

Date/Time:

08/01/2024 08:35

Matrix:

Potable water

Sample Type:

Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	08/10/24 16:21	

Sample ID:

Hatikvah International Academy

Charter School - 7 Lexington Ave., East Brunswick, NJ 08816/

Front Door #1

Site:

Collection Date/Time:

08/01/2024

Matrix: Potable water

Sample Type:

Lab Sample ID:

Grab

240805038-02

Lab Cert SM Analyte Method DF Sample Result MCL Rep. Limit **MDL** Analysis Date/Time Qualifiers No. Lead, Total Recoverable EPA 200.9 1 < 0.00100 mg/l 0.015 0.00100 0.00055 20044 08/10/24 17:12

Sample ID:

Hatikvah International Academy Charter School - 7 Lexington

Ave., East Brunswick, NJ 08816/

Site:

Lab Sample ID:

240805038-03

#2 Girls Bathroom

08/01/2024

08:39

08:43

08:37

Matrix:

Potable water

Date/Time: Sample Type:

Collection

Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	08/10/24 17:15	

Sample ID:

Hatikvah International Academy

Charter School - 7 Lexington Ave., East Brunswick, NJ 08816/

#3 Commons

Lab Sample ID:

240805038-04

Site:

Collection Date/Time:

08/01/2024

Matrix: Potable water Sample Type:

Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	08/10/24 17:21	



Sample ID: Hatikvah International Academy

Charter School - 7 Lexington Ave., East Brunswick, NJ 08816/

#4 L M-160

Site:

Site:

Collection Date/Time:

Lab Sample ID:

08:45

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	08/10/24 17:29	

Sample ID: Hatikvah International Academy

Charter School - 7 Lexington Ave., East Brunswick, NJ 08816/

#5 R - M-157

Collection Date/Time:

Lab Sample ID:

08/01/2024 08:46

240805038-06

240805038-05

08/01/2024

Matrix: Potable water

Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	08/10/24 17:32	

Sample ID: Hatikvah International Academy

Charter School - 7 Lexington Ave., East Brunswick, NJ 08816/

#6 M - 185

Site:

Site:

Lab Sample ID:

240805038-07

Collection

Date/Time:

08/01/2024 08:48

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	08/10/24 17:35	

Sample ID: Hatikvah International Academy

> Charter School - 7 Lexington Ave., East Brunswick, NJ 08816/

#7 M - 177

Collection Date/Time:

Lab Sample ID:

240805038-08

08/01/2024 08:51

Matrix: Potable water

Sample Type:

Grab

				1 71						
Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	08/10/24 17:38	

Main Lab certified by NJ Dept. of Health, NJDEP-TNI, NY Dept. of Health #11550 and PADEP #68-03680

Main Lab certified by NJ Dept. of Health, N.DEP-TNI, NY Dept. of Health #11550 and PADEP #68-03680